



# City of Prineville

Drinking Water  
Quality Report  
2017

Welcome to our 2017 Annual Water Quality Report. City of Prineville continues to meet, or exceed, all state and federal standards and regulations. Our company thrives on providing the highest quality water possible for our customers and future generations.

#### How to access more information on our water system

On the internet type in <https://yourwater.oregon.gov/>, under the blue box that has Drinking Water Program choose WS ID Look up, in the box type in 00682 and click View Results. You can scroll to the bottom and choose options to browse information for City of Prineville.



## Our Water

Our groundwater wells are recharged by precipitation infiltrating the soil surface, then percolates deep into the ground to recharge the aquifers. Water travels through the ground and is filtered naturally underground. The water is then pumped from the ground and piped to your home for drinking.

### An Important Message from the Environmental Protection Agency

The sources of (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals and human activity.

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and Herbicides**, comes from agricultural, urban storm-water runoff, and residential uses.

**Organic Chemical Contaminants**, synthetic and volatile organic chemicals are byproducts of industrial processes and petroleum production, and also from gas stations, urban storm-water runoff, and septic systems.

**Radioactive Contaminants**, Naturally occurring or the result of oil and gas production and mining activities.

Drinking water and bottled water may contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

### Important Information About Water and Your Health

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/Aids or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants. **For more information call the Safe Drinking Water Hot Line 1-800-426-4791. Additional information can be found on the CDC website: [www.cdc.gov/healthywater/drinking/public/faq.html](http://www.cdc.gov/healthywater/drinking/public/faq.html).**

### Lead in Drinking Water....Are You at Risk?

Elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Prineville is responsible for providing high quality drinking water to your tap, we cannot control the variety of materials used in plumbing components in your home. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water to drink or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>, or [www.leadline.org](http://www.leadline.org), or by contacting Edge Analytical, drinking water testing laboratory 541-639-8425.

*You can see our most recent test results in the data table below. We are required to report only those substances that were present at detectable levels. We are allowed to monitor for some contaminants less than once per year, therefore some of the data can be more than one year old.*

*If after reading this report and you still have questions, please feel free to contact our office 541-447-5627, or attend one of regular scheduled meetings held the 2nd and 4th Tuesday of each month.*

Primary Standards (directly related to the safety of drinking water)						
Inorganic Contaminants	Units	MCL	MCLG	Range/Result	Did a Violation occur ?	Likely Source
2017 - Arsenic	ppb	10	0	2.0	No	Erosion of natural deposits
2017 - Barium	ppm	2	2	0.006	No	Erosion of natural deposits
2017 - Chromium	ppb	100	100	2.0	No	Erosion of natural deposits
2017 - Fluoride	ppm	4	4	0.67	No	Erosion of natural deposits
2017 - Nitrate	ppm	10	10	0 - 3.87	No	Erosion of natural deposits
Unregulated Contaminants						
2017 - *Sodium	ppm	N/A	N/A	39.0	No	Erosion of natural deposits
*Contact your family doctor if you are on a sodium restricted diet.						
Radiological Contaminants	Units	MCL	MCLG	Range/Result	Did a Violation occur ?	Likely Source
2015 - Radium	pCi/l	5	0	0 - 1.4	No	Erosion of natural deposits
2017 - Uranium	ppb	30	0	2.0 - 4.0	No	Erosion of natural deposits
Lead and Copper	Units	MCLG	AL	90 <sup>th</sup> %	Did a Violation occur ?	Likely Source
2015 - Copper	ppm	1.3	1.3	0.14	No	Household plumbing
2015 - Lead	ppb	15	0	1.0	No	Household plumbing
Disinfection-Byproducts	Unit	MCL	MCLG	Range/Result	Did a Violation occur ?	Likely Source
2017 - Trihalomethane	ppb	80	N/A	1.5 - 4.6	No	By-Product of drinking water disinfection
2017 - Chlorine Residuals	ppm	4	4	0.02 - 1.09	No	By-Product of drinking water disinfection
Microbiological	MCL	MCLG	Positive Results	Did a Violation occur ?	Likely Source	
2017 - Total Coliform	TT	N/A	0 - 1	No	Naturally present in the environment	
A routine coliform bacteria sample was positive for total coliforms collected in November 2017. Follow up coliform bacteria samples were absent of any coliform bacteria. Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present. No violations occurred.						

- **AL - Action Level**, the concentration of a contaminant which if exceeded, triggers treatment or other requirements.
- **EPA - Environmental Protection Agency**, sets water quality standards and establishes methods and monitoring requirements for water utilities.
- **MCL - Maximum Contaminant Level**, the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.
- **MCLG - Maximum Contaminant Level Goal**, the level of a contaminant in drinking water which there is no known or expected risk to health. MCLG's allow a margin of safety.
- **PPB - Parts Per Billion**, the equivalent of one second in 32 years.
- **PPM - Parts Per Million**, the equivalent of one second in 12 days.
- **pCi/l - Picocuries Per Liter**, a measure of radioactivity.
- **Result** - the column that shows you what level of contaminant was found in the water you drink.
- **TT - Treatment Technique**, a required process intended to reduce the level of a contaminant in drinking water.

#### City of Prineville Source Assessment

An assessment of our water system has been completed by the Department of Human Services to determine susceptibility to potential sources of contamination. A copy is on file by contacting the office @ 541.447.5627.